




# *Economic Effect from Employment of New Russian Fuel at Czech NPPs*

8. 6. 2011

Pavel Veselý

CEZ, a. s.

Czech Republic



**TEMLIN NPP**

**NPP Temelín 2 × 1000 MWe**

**NPP Dukovany 4 x 440 MWe**



**DUKOVANY NPP**



## NPP OPERATED BY ČEZ - ACTUAL INSTALLED POWER

### **NPP Dukovany:**

- **Unit 1 ... ~ 500 MWe (2011)**
- **Unit 2 ... ~ 462 MWe**
- **Unit 3 ... ~ 500 MWe**
- **Unit 4 ... ~ 500 MWe**
- **TOTAL ~ 1962 MWe**

### **NPP Temelín :**

**Unit 1 , 2 ... ~ 2 x 1012 MWe**



## NPP OPERATED BY ČEZ - FUEL VENDORS

### NPP Dukovany :

Since 1985 operated with VVER 440 Fuel - JSC TVEL, (see below)

- extensive experience with fuel operation
- since 2009 ... power uprate licensed up to 105%

### NPP Temelín:

Unit 1 - till 2010: VVER 1000 fuel type VVANTAGE 6, Westinghouse  
full scale core refuelling: VV6 —▶ TVSA-T, JSC TVEL

Unit 2 – till 2011: VVER 1000 fuel type VVANTAGE 6, Westinghouse  
full scale core refuelling: VV6 —▶ TVSA-T, JSC TVEL

Experience with fuel TVSA-T -only one operation period on Pnom (3000 MWt);  
reference design cycle is five year cycle, 320 FPD, 36 FA per reload,

**Power Uprate Project up to 104% is just going on (2012)**



# NPP DUKOVANY - HISTORY OF FUEL CYCLE

## Basic Design: 3-years

- WFA 3,6 %
- CFA 2,4 %
- average 116 FAs

## 4-years cycle


- WFA(prof.) 3.82 %
- CFA 3,6 %
- average 87 FAs

## 5-years cycle

- WFA(Gd) 4.38 % (Gd-1)
- WFA(Gd) 4.25 % (Gd-2+)
- CFA 3,82 %
- average 72 FAs

## 5-y with Nr = 1444 / 1485 MW<sub>t</sub>

- WFA(Gd) 4.38% (Gd-2M(+))
- WFA(Gd) 4.76% (Gd-2X)
- CFA(Gd) 4,25 % (Gd-2+)
- CFA(Gd) 4,38 % (Gd-2M)
- average 72 FAs





# NPP DUKOVANY – FUEL UTILISATION OVERVIEW

## TIME APPROACH

Year =>	2007	2008	2009	2010	2011	2012	2013	2014	2015
Unit 1	I&C				105%				108%?
Unit 2		I&C				105%			
Unit 3			105%						
Unit 4			I&C	105%					



- profiled fuel 3.82%



- Gd-1 – 4.38%



- Gd-2 (+) – 4.25%



- Gd-2M – 4.38%



- Gd-2M+X – 4.38/4.76%

I&C – finalization of I&C reconstruction

105% – power uprating

108% – power uprating ???



## Fuel Cycle Tendency:

- continuous modernization and more efficient fuel loading strategy
- relatively high load factors for NPP
- continuous growth of average and maximum fuel burn-up
- increasing number of Fuel Assemblies loaded into fifth cycle with the perspective of transition to six-year cycle
- no failed fuel type Gd-1 and Gd-2 during NPP operation at the moment



# RELOAD BATCHES THE SAME FROM 2002 - 2011 TRANSITION TO 5-YEAR CYCLE

**FA** = Fuel Assembly  
**CA** = Control Assembly

**FA + CA** = Number of FAs and CAs in reload batch  
**FA5** = Fuel assemblies utilized in fifth year


Year	UNIT 1		UNIT 2		UNIT 3		UNIT 4		NPP FA5/6
	FA + CA	FA5	FA + CA	FA5	FA + CA	FA5/6	FA + CA	FA5	
2002	84 + 6	0	72 + 6	12	72 + 12	6	84 + 6	0	18
2005	60 + 12	24	54 + 12	48	<u>72 + 6</u>	<u>24</u>	66+6+12	49/6	145/6
2006	66 + 6	61	60 + 6	55	54 + 12	43/12	66 + 6	61/6	220/18
2009	60 + 12	61	66 + 12	61/6	<u>72 + 6</u>	67/6	54+6	55	244/12
2010	66+6	55	60+6	55/6	<u>54+6</u>	55	60+12	61	226/6
2011	66+6*	67	54+6	55	<u>60+6</u>	55/12	66+6*	67	244/12



Profiled fuel assemblies (mean enrichment 3,82wt%)



Gd-1 fuel assemblies




Gd-2 fuel assemblies





# FUEL ASSEMBLY WITH Gd - FIRST GENERATION

Gd-1 with mean enrichment 4.38 wt%  $U^{235}$






# NPP DUKOVANY UNIT 2

## 3<sup>rd</sup> TRANSIENT RELOAD WITH Gd-1 FUEL (2005/2006)

### Unit 2, Cycle 20



**Gd-1**


Fuel type	Enrich. [%]	Year	Nº FA [pl]
	3.82	0	0 +12 CA
	4.38	0	54
	3.82	1	0 +6 CA
	4.38	1	66
	3.82	2	0 +12 CA
	4.38	1	72
	3.82	3	72 +7 CA
	3.82	4	48



# Gd-2 FUEL ASSEMBLY


## MEAN ENRICHMENT 4,25 wt% U<sup>235</sup>

### TVEL Design Gd-2



- 4.4 %
- 4.0 %
- Gd 4.0 %  
+3.35% Gd<sub>2</sub>O<sub>3</sub>
- 3.6 %

### Optimized Design CEZ/SKODA Gd-2+




- 4.4 %
- 4.6 %
- 3.7 %
- Gd 4.0 %  
+3.35% Gd<sub>2</sub>O<sub>3</sub>
- 3.3 %









# NPP DUKOVANY UNIT 3

## 1<sup>ST</sup> RELOAD WITH Gd-2 FUEL, 1375 MWT (2005/2006)

### Unit 3, Cycle 19




Gd-2

Fuel type	Enrich. [%]	Year	Nº FA [pl]
	3.82	0	0 +6 CA
	4.25	0	72
	3.82	1	66 +12 CA
	3.82	2	78 +6 CA
	3.82	3	72 +13 CA
	3.82	4	24



# Gd-2 M FUEL


## MEAN ENRICHMENT 4,38/4,25 wt% U<sup>235</sup>





# NPP DUKOVANY UNIT 3


## 2011 RELOAD WITH Gd-2M FUEL, 1444 MWT






# NPP DUKOVANY

## LENGTH OF THE CYCLE AND MEAN LIFETIME OF FA





# AVERAGE BURN-UP OF FA AND AVERAGE NUMBER FA PER RELOAD







## NEW FUEL CYCLE EVALUATION

### New Fuel Cycle implementation – economic evaluation and sensitivity analyses are made

Cost per KWh:

$$C = CF + Cop + Cad$$

**CF** – fuel cost in accordance with 1)2) ( U+SWU+Fab and **Reference Fuel Cycle (RFC)**)

**Cop** – operation cost ( load factor, length of outage)

**Cad** – addition cost (summary of licensing work for new fuel, impact on management of fresh and spent fuel, additional efforts)

1-The Economics of the Nuclear Fuel Cycle, Nuclear Energy Agency, OECD 14. 2003

2-Zu.M.Semchenkov, et all. Fuel cycles of VVER-440, 17th Symposium of AER, September 24-29, 2007, Yalta, Crimea,Ukraine



## PROCEDURE FOR INCREASE OF FUEL CYCLE EFFECTIVITY

### Two „optimization“ procedures (SW) :

- „OPTIMAL“ – product of NRI Řež
- „OPAL“ – developed in Škoda

### Objective :

- calculation of reference cycle parameters (for Contract RFC )
- making single cycle optimization of each reload
- making data for multi cycle optimization



## PROCEDURE FOR INCREASING FUEL CYCLE EFFECTIVITY

### Results of fuel cycle optimizing :

- Design of optimal reloads – experience confirmed extension of design cycle with comparative RFC - practically up to 10 days or more in individual cases; **or real reduction of FA number in reload (the direct saving of the fuel cost)**
- Supplementary operation time for NPP and shortening the outage period (minimal length of outage is now on the level ~ 22 day)
- Increase the load factor of NPP and burn up of unloaded FA ►►  
**this part represents the main source of future profit**

### Important presumption :

- Reliability of the fuel (now changes of core design in time stress)


Remark – Zero leak for FA type Gd1 and Gd2 (from 2003)



# EXAMPLE OF FUEL CYCLE STUDY BY OPTIMAL

## CYCLE 25 FINAL 3D RESULTS - $K_q/T_{eff}$

FdH < 1.530 C1; < 1.533 C2; < 1.535 C3; < 1.537 C4; < 1.540 C5; < 1.543 C6; < 1.545 C7





## NPP DUKOVANY: BURN UP OF UNLOADED FA AVERAGE/MAXIMUM (MWD/KG U)

	2008	2009	2010	2011
U-1 (Gd-1)	50.5 / 51.6	50.1 / 51.9	50.7 / 51.4	–
U-2 (Gd-1)	51.2 / 56.3	51.1 / 51.8	51.6 / 52.0	51.1 / 52.0
U-4 (Gd-1)	–	52.2 / 52.6	51.8 / 53.3	–
U-3 (Gd-2)	–	–	50.5 / 52.3	51.4 / 52.4



# LICENSING OF THE NEW FUEL – IMPORTANT PART OF ADDITIONAL COST

## Requirements of The Czech State Office for Nuclear Safety (SONS):

- New fuel types and fuel cycles should be licensed in accordance with the Czech “Atomic” Act and with the international practice (IAEA documents, US NRC codes, NUREG 800, ...)

### Licensing documents require:

- Amendment to SAR(TOB) and topical reports prepared by the fuel vendor (part of the fuel delivery contract )
- Topical reports (safety analyses and supplementary alternative safety analyses on the deterministic or BE approach) and Final Amendments to SAR prepared by national Czech organizations (separate agreement with CEZ)
- Special records for RAIs explanation

Reload safety analysis Checklist – standard routine

**Additional cost of licensing – a few million USD per licensing case**



# FUEL MANAGEMENT AND HANDLING

## PART OF ADDITIONAL COST

### Fuel Management and Handling:

Implementation of New Fuel – increase of enrichment and mass of fuel in FA → subcriticality impact (verification of subcriticality and coolability of SFP are part of licensing work)

Lower volume of fuel per reload → prolongation of fuel cooling in SFP (7-9 year) before loading to Cask (CASTOR 440 M)

### Impact of new fuel on back-end activities must be taken into account:

- Increased radiation dose (neutron factor) and residual heat from high burnup fuel and
- Subcriticality problem → virtually can decrease number of FA per Cask → increase the cost of spent fuel management

**Increase of back-end cost represents the important factor which is able to break the tendency to increase burn up of fuel – we can lose, roughly speaking, e.g. up to thousand EUR per FA for additional dry storage activities**



# NPP DUKOVANY: NEW REQUIREMENTS FOR FUEL CYCLE FOR THE NEXT PERIOD OF OPERATION

## New Requirements:

- Increase the power of NPP up to 1485 MWt (licensed power)
- Extension of length of operation up to 335 FPD for power 1444 or 1485 MWt
- Execution of five year cycle (L<sup>3</sup>P «loading pattern» ) 66 – 72 FA per reload with perspective next 20 year of operation (low neutron dose on vessel)
- Goal – increase production from 14 TWhe up to 16 TWhe






# ADVANCED FUEL CYCLE AFTER 2014 - TWO OPTIONS

**QFS; Q6S**


Average enrichment  
4,757143 w% U<sup>235</sup>



- 4.95w% U<sup>235</sup>
- 4.40w% U<sup>235</sup>
- Gd 4.40w% U<sup>235</sup>  
+3.35 % Gd<sub>2</sub>O<sub>3</sub>
- 4.20w% U<sup>235</sup>

**SLO; SL6; SLF**

Average enrichment  
4,873810 w%U<sup>235</sup>



- 4.95w% U<sup>235</sup>
- 4.60w% U<sup>235</sup>
- Gd 4.40w% U<sup>235</sup>  
+3.35 % Gd<sub>2</sub>O<sub>3</sub>




## New Fuel - Type Gd 2M+

Parameters	TVEL		TVEG	
	FA	CFA	FA	CFA
FR Length , (mm)	2601,5	2540	2601,5	2540
Fuel Column length,( mm)	2480	2360	2480	2360
Fuel mass per FR ,(g)	1230	1170	1141	1085
<b>Cladding tube (E110):</b>				
Outside diameter (mm)	9,1±0,04			
Inside diameter (mm)	7,93 <sup>+0,06</sup>		7,73 <sup>+0,06</sup>	
<b>Fuel pellets :</b>				
Outside diameter (mm)	7,80 <sub>-0,03</sub>		7,60 <sub>-0,03</sub>	
Inside diameter (mm)	-		1,2 <sup>+0,3</sup>	
grain size(μm)	≤ 25		6-25	




# THE MAXIMAL VALUE OF $K_r$ FOR DIFFERENT TYPES OF FUEL






# OPTIMIZED RELOAD WITH THE FUEL TYPE QFS (4,76%)





# OPTIMIZED RELOAD WITH THE FUEL TYPE SLF (4,87%)





## BETTER STRATEGY OF CFAs IN GENERAL

Strategy	Number of CFA/average	Cycle [years]
12 – 12	12	3.08
<b>12 – 6</b> Present situation	<b>9</b>	<b>4.11</b>
12 – 6 – 6	8	4.63
<b>12 – 6 – 6 – 6</b> Advantage cycle CFA	<b>7.5</b>	<b>4.93</b>
12 – 6 – 6 – 6 – 6	7.2	5.14



## EXPECTATION FROM NEW CFAS STRATEGY

### Burn-ups

a) inner positions - ~50 MWd/kgU after 4 years

– will be **discharged**

b) groups **3** and **4** - ~40 MWd/kgU after 4 years


– enable **use for 1-2 cycles**

→ central position **6c** in 5-th year from group **3**

→ group **1** – 5-th and 6-th year from group **4**



# NPP DUKOVANY: Dependence of the Consumption of U235 and Relative Fuel Cycle Costs for advanced fuel cycles (example)







# FUEL CYCLE CHARACTERISTICS AND COMPARATION

FA = Fuel Assembly

FPD = Full Power Days

CA = Control Assembly

RFCC = Relative Fuel Cycle Costs

FA Type : CA Type :	Profiled fuel Profiled fuel	Gd-1 Profiled fuel	Gd-2 / Gd-2+ <sup>1)</sup> Profiled fuel	Gd-2M Profiled fuel
Enrichment [wt% U235] FA / CA	3,82 / 3,82	4,38 / 3,82	4,25 / 3,82	4,38 / 4,25 <sup>1)</sup>
Average reload batch	78 FA + 6 CA	63 FA + 9 CA	63 FA + 9 CA	63 FA + 9 CA (60+6)
Average cycle length [FPD]	310	315	325	325*)(315)*
U / MWd [kg]	0,204 (0,207)	0,183	0,178	0,177(167)
SWU / MWD	0,117	0,128	0,122	0,124(118)
RFCC [%]	100	95	94	92(89)

<sup>1)</sup> Improve profiled fuel

<sup>\*</sup> 1444 MWt



# FUEL CYCLE CHARACTERISTICS AND COMPARATION - NEW EXPECTATION

<b>FA Type</b>	<b>Gd-2M+</b>	<b>TVSA-T</b>
<b>NPP</b>	<b>440</b>	<b>1000</b>
<b>Enrichment</b>	<b>4,76/4,38</b>	<b>4,53 **</b>
<b>Avereg reload Batch</b>	<b>60+7,5</b>	<b>36</b>
<b>Average cycle length (FPD)</b>	<b>365 *</b>	<b>315</b>
<b>U/MWd (kg)</b>	<b>0,182</b>	<b>0,168</b>
<b>SWU/MWd</b>	<b>0,112</b>	<b>0,120</b>
<b>RFCC</b>	<b>92,7</b>	

\*) 1444 MWt

\*\*\*) FA with blanket



# CONCLUSIONS

- Five year cycle with Gd-1 and Gd-2 fuel was successfully realized; good agreement between calculated and measured core data acknowledged; low-leakage core design adopted for all type of FA (L3P)
- Implementation and next innovation of advanced fuel cycles saved the fuel cost and stabilize the production cost ; Number of FAs per reload were reduced to level 66 to 72 for fuel Gd-2M also for operation on the power level 1444 MWt for VVER 440
- Next upgrade of the fuel design shall be specific for future requirements of the ČEZ. New type of fuel for uprated power up to 108 % ( Gd-2M+ type in perspective) shall be procured by the Fuel Contract and it is assumed to be licensed in Dukovany in period 2012- 2014
- New Fuel type TVSA-T and RCCA were licensed in 2010 and loaded in to NPP Temelín; power uprate up to 104 % and scheduled RFC shall be reached during a few next year


**„Requirements of the Regulatory Body (SONS) to keep the highest level of nuclear safety are the basic condition and priority for any changes in fuel cycle“**

Thank you for your attention





# CFAs GROUPS MAP





## NEW CFAS STRATEGY 12-6-6-6

- strategy **12 – 6 – 6 – 6 – ...** fresh CFAs in 4 sequential loadings
  - 12 CFA to groups **3** and **4**
  - 6 CFA to group **2**
  - possible movement: **2** → **5** → **6p** → **6p**
  - 2 loops
    - inner positions (**2, 5, 6p**)
    - outer positions (**3, 4, 1, 6c**)
- strategy in period of testing